



COMBINATION CURB, GUTTER, SIDEWALK

NOTES:

1. CONCRETE SHALL BE 6 SACK MINIMUM CLASS "B" 3000 LB. FIELD CURE/SQ. IN. AT 28 DAYS.
2. EXPANSION JOINT MATERIAL SHALL BE NON-EXTRUDING AND RESILIENT TYPE TO MEET AASHTO SPEC. M-213.
3. ANY OVER-EXCAVATION SHALL BE REPLACED WITH GRANULAR BACKFILL COMPACTED TO 95% MAXIMUM DRY DENSITY AS DETERMINED BY ASTM D-698.
4. TYPE 1 COMBINATION CURB & GUTTER & SIDEWALK IS FOR USE AND NON-THRU TRAFFIC STREETS ONLY.



CITY of DELTA
 360 MAIN STREET
 DELTA, CO 81416

TYPE 1 COMBINATION CURB,
 GUTTER & SIDEWALK

DATE: JUNE 1999

SHEET R9 OF 24